

**ALL ELECTRICAL CONNECTIONS NEED TO BE DONE  
BY A CERTIFIED ELECTRICIAN.**

The following is a list of instructions for installing a fusible disconnect to an FS300:

1. Mount fusible disconnect switch onto the mounting channel using the hardware provided.
2. Feed wires through the pulling elbow/conduit assembly and insert pipe through hole in mast.
3. Connect wires to fusible disconnect switch.
4. Finish electrical terminations to equipment.
5. Install fusing.

Refer to Drawing FSD Assembly for additional references.